

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7080-2177:0100

CATEGORY: Extinguishing Systems

LISTEE: Fireaway, Inc., 5852 Baker Road, Minnetonka, MN 55345
Contact: Anthony Gee (952) 847-4660 Fax (952) 935-9757
Email: agee@statx.com

DESIGN: Models 30E, 60E, 60E long, 100E, 250E, 500E, 1000E, 1500E and 2500E Stat-X condensed aerosol generators.
Models G30, G60, G100, G250, G500, G1000, G1500 and G2500 Aero-K condensed aerosol generators.
Mounting bracket for Models G30, G60, G100, G250, G500, G1000, G1500 and G2500.
Mounting bracket for Models 30E, 60E, 100E, 250E, 500E, 1000E, 1500E and 2500E.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name , model number and UL label.

APPROVAL: Listed as condensed aerosol generators for Class A surface burning and Class B and C category hazards. Not approved for use in hazardous locations. Authority having jurisdiction shall be consulted prior to installation. Refer to listee's Installation Instructions Manual for details.

11-13-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **November 13, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division